

**2006-2008 Discharge Monitoring Report Data****UPDES No. UT0000124 (USA Pan American Lease, 7 miles SE of Vernal, UT)****Western Energy Operating, LLC Outfall 001 (formerly Whiting Oil & Gas)**

FACILITY	ADDRESS	CONTACT	Quarter of 2006	Number of Violations	Avg. Flow (MGD)	Max. Flow (MGD)	PH MIN	PH MAX	BOD 5-day Max.(mg/L)	TSS (mg/L) Max.	TDS (mg/L) Max.	Oil & Grease (mg/L)	WET pass/fail
Western Energy Operating Outfall 001	439 N. Conwell St. Casper, WY 82601	Kim Bradshaw or Paul Hannah (307) 472-0720	Feb/Mar/Apr	0	0.954	1.081	7.8	7.8	14.0	<10.0	1400	2	Pass
			May/Jun/Jul	0	1.316	1.317	7.8	7.8	9.0	<10.0	1430	2.0	Pass
			Aug/Sept/Oct	0	1.32	1.32	8.0	8.0	15	<10.0	1420	2.0	Pass
			Nov/Dec/Jan	0	1.34	1.35	7.7	7.7	14	<3.0	1600	6.6	Pass
FACILITY	ADDRESS	CONTACT	Quarter of 2007	Number of Violations									
Western Energy Operating Outfall 001	439 N. Conwell St. Casper, WY 82601	Kim Bradshaw or Paul Hannah (307) 472-0720	Feb/Mar/Apr	0	0.76	1.57	7.80	7.80	21	<3.0	1300	6.1	Fail/Pass
			May/Jun/Jul	0	0.75	0.95	7.93	7.93	18	<3.0	1300	7.5	Fail/Pass
			Aug/Sept/Oct	0	0.67	0.72	8.1	8.1	19	<3.0	1300	7	Pass
			Nov/Dec/Jan	0	0.67	0.72	8.10	8.10	19	3.0	1300	7.2	Pass
FACILITY	ADDRESS	CONTACT	Quarter of 2008	Number of Violations									
Western Energy Operating Outfall 001	439 N. Conwell St. Casper, WY 82601	Kim Bradshaw or Paul Hannah (307) 472-0720	Feb/Mar/Apr	0	1.43	1.55	7.53	7.53	<5.0	3.0	1400	3.6	Pass
			May/Jun/Jul	1	0.97	0.84	8.07	8.07	<6.0	<3.0	780	11	Pass
			Aug/Sept/Oct	0	ND	ND	ND	ND	ND	ND	ND	ND	ND
			Nov/Dec/Jan	0	ND	ND	ND	ND	ND	ND	ND	ND	ND
			PERMIT LIMITS:		1.63		6.5	9	25	25	2400	10	Pass
			AVERAGES:		1.018	1.142	7.88		16.1	3	1323	5.5	Pass

ND = No Discharge, facility idled of as July 2008